BENTLY NEVADA MODEL-SPECIFIC PRODUCT

146054-12-05-02-05

146054-12-05-02-05 is a 3/8-24 UNF ceramic-capped proximity probe in the Bently Nevada 3300 Ceramic Capped Probe. This independent product manual summarizes the exact decoded configuration for procurement and installation review.

PRODUCT FAMILY	PRODUCT TYPE
3300 Ceramic Capped Probe	**3/8-24 UNF ceramic-capped proximity probe**

Exact model configuration

CONFIGURATION FIELD	DECODED VALUE
Part number	**146054-12-05-02-05**
Manufacturer	**Bently Nevada**
Overall case length	**1.2 in**
Total length	**0.5 m (1.6 ft)**
Connector / cable	**ClickLoc connector; standard cable**
Armor	**Without armor**
Probe tip material	**Alumina ceramic**
Approvals	**CSA, ATEX and IECEx**

Application fit

- Use 146054-12-05-02-05 only in the documented 3300 Ceramic Capped Probe application.
- Confirm the complete part number, mounting, cable routing and matched-system requirements before replacement.
- Verify the installed unit and current Bently Nevada documentation before installation or commissioning.

SYSTEM-LEVEL PERFORMANCE	INSTALLATION NOTE
Overall case length: 1.2 in **Total length:** 0.5 m (1.6 ft) **Connector / cable:** ClickLoc connector; standard cable	Performance and configuration information applies only to the exact matched transducer or monitoring system. Do not treat product-only ordering data as a complete-system calibration certificate.

MODEL-SPECIFIC ENGINEERING REFERENCE

Before ordering 146054-12-05-02-05

Use this page as a controlled procurement checklist. It does not replace the manufacturer datasheet, installation instructions or approval certificate.

Ordering limits and selected values

CONFIGURATION FIELD	DECODED VALUE
Overall case length	**1.2 in**
Total length	**0.5 m (1.6 ft)**
Connector / cable	**ClickLoc connector; standard cable**
Armor	**Without armor**
Probe tip material	**Alumina ceramic**

Procurement checklist

- Confirm the complete ordering code 146054-12-05-02-05 and readable nameplate before shipment.
- Confirm the product family and product type against the installed item.
- Confirm every decoded length, thread, connector, mounting and approval option.
- Confirm compatibility with the complete measurement or monitoring system.
- Confirm approval markings and certificate scope for the installation location.

DIRECT SALES INQUIRY

Send the full model **146054-12-05-02-05**, quantity, delivery country, and a clear nameplate or installation photo.

Sandy Lin | plcinfo@mooreplc.com | WhatsApp /Phone: +86 18020776786

Source and document status

Technical basis	Baker Hughes 3300 Ceramic Capped Probe Datasheet 172932 Rev. J
Publisher	Moore Automation - independent industrial automation supplier.
Document status	Independent product manual; not a manufacturer-issued datasheet, conformity certificate or calibration certificate.
Important	Verify availability, revision status, compatibility, nameplate data and regulatory requirements before ordering.