GE FANUC MODEL-SPECIFIC PRODUCT

IC697BEM761

IC697BEM761 is a GE Fanuc IC600 I/O Interface Module. This independent manual keeps the exact model visible and summarizes product-specific information recorded for procurement and configuration review.

PRODUCT FAMILY	PRODUCT TYPE
Series 90-70	**IC600 I/O Interface Module**

Exact model configuration

CONFIGURATION FIELD	DECODED VALUE
Displayed model	**IC697BEM761**
Manufacturer	**GE Fanuc**
Product family	**Series 90-70**
Product type	**IC600 I/O Interface Module**
Interface purpose	**IC697 I/O racks on an IC600 I/O bus**
Standard rack capacity	**8 IC697 racks maximum**
Backplane demand	**1.3 A from the 5 V bus**

Application fit

- Retain an IC600 control system while interfacing compatible IC697 I/O racks.
- Allocate rack-dependent addresses before changing rack numbers or module positions.
- Treat complementary addressing as a separate validated configuration.

PRODUCT-SPECIFIC REFERENCE	INSTALLATION NOTE
IC697 I/O racks on an IC600 I/O bus 8 IC697 racks maximum 1.3 A from the 5 V bus	Install in slot 1 of the IC697 rack. The IC600 PLC needs at least 8K registers; reserve the control/status registers and I/O references listed in the manual.

MODEL-SPECIFIC ENGINEERING REFERENCE

Before ordering IC697BEM761

Use this page as a controlled procurement checklist. It does not replace the manufacturer datasheet, installation instructions or approval certificate.

Ordering limits and selected values

CONFIGURATION FIELD	DECODED VALUE
Manufacturer	**GE Fanuc**
Product family	**Series 90-70**
Product type	**IC600 I/O Interface Module**
Interface purpose	**IC697 I/O racks on an IC600 I/O bus**
Standard rack capacity	**8 IC697 racks maximum**
Backplane demand	**1.3 A from the 5 V bus**

Procurement checklist

- Confirm the complete ordering code IC697BEM761 and readable nameplate before shipment.
- Photograph rack-number jumpers and retain the main and auxiliary I/O maps.
- Confirm the host register capacity and exclude reserved references from field I/O.
- Record upstream/downstream cables and end-of-chain termination positions.
- After power-off replacement, check all three status LEDs and downstream racks.

DIRECT SALES INQUIRY

Send the full model **IC697BEM761**, quantity, delivery country, and a clear nameplate or installation photo.

Sandy Lin | plcinfo@mooreplc.com | WhatsApp /Phone: +86 18020776786

Source and document status

Technical basis	GE Fanuc GFK-0096F, July 1995, pages 1-7; reproduced in GFK-0600F, section 67.
Publisher	Moore Automation - independent industrial automation supplier.
Document status	Independent product manual; not a manufacturer-issued datasheet, conformity certificate or calibration certificate.
Important	Verify availability, revision status, compatibility, nameplate data and regulatory requirements before ordering.