GE FANUC FIELD CONTROL EXACT-MODEL PRODUCT

IC670MDL642

IC670MDL642 provides sixteen 125 VDC discrete inputs in one group for positive- or negative-logic operation. The external supply orientation determines the logic convention for the complete group.

PRODUCT FAMILY	PRODUCT TYPE
Field Control	**125 VDC 16-Point Positive/Negative Discrete Input Module**

Exact model configuration

CONFIGURATION FIELD	VERIFIED VALUE / CHECK
Displayed model	**IC670MDL642**
Manufacturer	**GE Fanuc**
Product family	**Field Control**
Product type	**125 VDC 16-Point Positive/Negative Discrete Input Module**
Input points	**16 in one group**
Rated voltage	**125 VDC**
Input range	**0 to 150 VDC**
Input current	**2.5 mA per point at 125 VDC**
On-state voltage	**±79 to ±150 VDC**
Off-state voltage	**0 to ±30 VDC**
BIU current	**77 mA maximum**
Response	**6 ms on typical; 6 ms off typical**
Isolation	**1500 VAC for 1 minute; 250 VAC continuous**
Country of origin	**USA**

Application fit

- Use only in a documented compatible GE Fanuc Field Control station.
- Match the exact catalog number, terminal block, BIU revision, field supply and saved I/O configuration before replacement.
- Remove field power where required, preserve channel wiring, and complete point-by-point commissioning before return to service.

PRODUCT-SPECIFIC REFERENCE	INSTALLATION NOTE
IC670MDL642 sixteen-point 125 VDC positive/negative logic input module.	Confirm high-voltage DC polarity, group common, input thresholds, isolation and safe work controls.

MODEL-SPECIFIC ENGINEERING REFERENCE

Before ordering IC670MDL642

Use this page as a controlled procurement checklist. It does not replace the manufacturer instruction sheet, wiring drawing, approval certificate, or site safety procedure.

Ordering limits and selected values

CONFIGURATION FIELD	VERIFIED VALUE / CHECK
Manufacturer	**GE Fanuc**
Product family	**Field Control**
Product type	**125 VDC 16-Point Positive/Negative Discrete Input Module**
Input points	**16 in one group**
Rated voltage	**125 VDC**
Input range	**0 to 150 VDC**
Input current	**2.5 mA per point at 125 VDC**
On-state voltage	**±79 to ±150 VDC**
Off-state voltage	**0 to ±30 VDC**
BIU current	**77 mA maximum**
Response	**6 ms on typical; 6 ms off typical**
Isolation	**1500 VAC for 1 minute; 250 VAC continuous**
Country of origin	**USA**

Procurement checklist

- Photograph the complete IC670MDL642 nameplate and hardware revision.
- Record the installed terminal block, BIU, slot and field-power arrangement.
- Back up the applicable I/O configuration, channel map, alarms and defaults.
- Verify wiring, polarity, isolation boundaries, grounding and protective devices.
- Commission every affected point and retain the signed test record.

DIRECT SALES INQUIRY

Send the full model **IC670MDL642**, quantity, delivery country, and a clear nameplate or installed-module photo.

Sandy Lin | plcinfo@mooreplc.com | WhatsApp /Phone: +86 18020776786

Source and document status

Technical basis	GE Fanuc Field Control I/O Modules User's Manual GFK-0826J (June 2002).
Publisher	Moore Automation - independent industrial automation supplier.
Document status	Independent product manual; not a manufacturer-issued datasheet, conformity certificate, or calibration certificate.
Important	Verify the complete nameplate, suffix, carrier or terminal hardware, wiring, approvals, and installed-system compatibility before ordering.