TECHNICAL & APPROVAL REFERENCE

# 330905-00-10-50-02-00
# 3300 XL NSv Proximity Probe

Model-specific ordering-code summary for identification, compatibility review and procurement verification.

## Exact ordering-code summary

| FIELD | MODEL-SPECIFIC VALUE |
|---|---|
| Item number | 330905-00-10-50-02-00 |
| Manufacturer / family | Bently Nevada / 3300 XL NSv |
| Probe mounting | M10 x 1, unarmored |
| Unthreaded length | 0 mm |
| Case length | 100 mm |
| Total probe length | 5.0 m (197 in) |
| Connection | Miniature ClickLoc; standard cable; no connector protector |
| Approval option | 00 - additional approval option not required |

MOORE AUTOMATION

## System context

The probe is one component of a matched 3300 XL NSv proximity transducer system. A complete measurement chain also requires the compatible 3300 NSv extension cable and 3300 XL NSv Proximitor Sensor. System performance values apply only when the probe, cable and sensor are correctly matched and installed under the manufacturer conditions.

| | |
|---|---|
| **IMPORTANT** | Confirm the complete nameplate, mounting geometry, case reach, cable route, connector clearance, target material and installed system length before replacement. |

VERIFICATION & DOCUMENT BASIS

# 330905-00-10-50-02-00 procurement checklist

## Verification before ordering

| FIELD | MODEL-SPECIFIC VALUE |
|---|---|
| 1. Identity | Match the complete ordering code 330905-00-10-50-02-00 and photograph the full nameplate. |
| 2. Mechanical fit | Confirm M10 x 1 mounting, 0 mm unthreaded length and 100 mm case length. |
| 3. Cable / connector | Confirm 5.0 m total probe length and Miniature ClickLoc standard-cable configuration. |
| 4. Matched system | Verify the extension cable and 3300 XL NSv Proximitor Sensor part numbers and electrical system length. |
| 5. Installation | Document cable routing, connector clearance, target material, gap, wiring and monitor configuration. |
| 6. Approval | The code specifies option 00; confirm the actual nameplate and project regulatory requirements. |

MOORE AUTOMATION

## Manufacturer-document basis

Technical values in this reference are transcribed from Baker Hughes / Bently Nevada 3300 XL NSv Proximity Transducer System documentation, including document 147385 Rev. R. Approval-option interpretation is checked against the Baker Hughes country-specific ordering-options guide, document 108M1756 Rev. AV. Manufacturer documentation remains controlling.

## Use note

This independent Moore Automation reference is provided to support model identification and procurement review. It does not replace the current manufacturer datasheet, installation manual, certification, project engineering review or the actual product nameplate.

| CONTACT MOORE AUTOMATION | Email: plcsale@mooreplc.com<br>WhatsApp / Phone: +86 18030235313<br>Website: www.dcsmodule.com |
|---|---|